



Certificate

No. SEBS-A.133641/14 V2.0

TÜV NORD Systems GmbH & Co. KG hereby certifies

ASTAVA B.V.

Industrieweg 30
7944 HS Meppel, Netherlands

that the

Interlocking Manifold, Types 1002, 2003, 1004 with Block-Bleed or Block-Bleed-Block Function

with the safety function "Operating Steps and Availability" for maintenance of pressure sensors is capable for safety related applications up to SIL 4 and meets the requirements listed in the following standard.

- IEC 61508: 2010 part 1 and part 2

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 5.1 / 04.19)

This certificate considers only maintenance and does not consider the usage of the system in safety instrumented systems with SIL classification.

Base of certification is the report SEBS-A.133641/14TB in the valid version.

This certificate entitles the holder to use the pictured safety approved mark.

Valid until: 2025-04-30

File reference: 8111929550

Hamburg, 2020-04-29



Bianca Pfuff

